

Annual Drinking Water Quality Report

FT MASSAC PWD

IL1275050

Annual Water Quality Report for the period of January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by FT MASSAC PWD is Purchased Ground Water.

For more information regarding this report contact: Name: David Travis
Phone: 618-543-7475

Este informe contiene informacion muy importante sobre el agua que usted bebe. Traduzcalo o hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

-Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

-Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

-Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

-Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

-Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Source Water Information

Source Water Name	Type of Water	Report Status	Location
CC 05-MILLSTONE MASTER METER FF IL1515050 TP04	GW	Active	AT MILLSTONE FT MASSAC B.S., 1 MILE STH. REESEVILLE, IL
CC 06-SOUTHWATER MASTER METER FF IL0030020 TP01	GW	Active	8364 SHAWNEE RD., ULLIN, IL

Source Water Assessment

Ft Massac PWD IL1275050

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings at the Ft. Massac Water District's office, 813 Joppa Road, Metropolis, IL at 7:00 p.m. on the 3rd Tuesday of each month. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by the Fort Massac Water District office or call our water operator at 618-543-7475. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Millstone PWD IL1515050

To determine Millstone PWD's susceptibility to groundwater contamination, a Well Site Survey, published in 1994 by the Illinois EPA, was reviewed. Based on information obtained in this document, one potential source of groundwater contamination is present that could pose a hazard to the groundwater pumped by the Millstone PWD community water supply wells. This site is a lime sludge lagoon located 50 feet from Well #5. Based on information provided by Millstone PWD's water supply officials, this lime sludge lagoon has changed its status (sludge removed) and the four wells listed in the site data table have been properly abandoned. The community's source water is susceptible to SOC contamination from non-point sources related to agricultural land use. Also, as a result of monitoring conducted at the wells and entry point to the distribution system, the land-use activities, and a source water protection initiative by the facility, the Millstone PWD's source water is not susceptible to VOC and IOC contamination. Furthermore, in anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that the Millstone PWD's wells are not vulnerable to viral contamination. This determination is based on the evaluation of the following criteria considered during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate viral contamination threat. However, having stated this, the "(U.S.) EPA is proposing to require States to identify systems in karst, gravel, and fractured rock aquifer systems as sensitive and these systems must perform routine source water monitoring". Because the community's wells are open to an unconfined sand and gravel aquifer, the Illinois EPA evaluated the well hydraulics associated with the Millstone PWD's well field. The amount overburden should provide an adequate degree of filtration to prevent the movement of pathogens into the wells.

Southwater PWD IL0030020

To determine Southwater, Inc's susceptibility to contamination, a well-site survey was recently conducted by the Illinois Rural Water Association in December 2002. Based upon a review of this information, there are 2 potential sources of groundwater contamination that could pose a hazard to groundwater utilized by Southwater Inc.'s community water supply wells. These potential sources include 2 above ground fuel storage tanks. In addition, information provided by the Leaking Underground Storage Tank and Remedial Project Management Sections of the Illinois EPA indicated additional sites with on-going remediation which may be of concern. Based upon this information, the Illinois EPA has determined that the Southwater, Inc. community water supply's source water is susceptible to contamination. As such, the Illinois EPA has provided 5-year recharge area calculations for the wells. The land use within the recharge area of the wells was analyzed as part of this susceptibility determination. This land use includes agricultural properties and floodplain.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

FT MASSAC PWD IL1275050 2024 Regulated Contaminants Detected

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment.

Lead and Copper

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Public Water Supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact Fort Massac Water District, David Travis at 618-543-7475. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Copper Range: not detected in 2024

Lead Range: not detected in 2024

To obtain a copy of the system's lead tap sampling data: Contact Fort Massac Water District at 618-543-7475

Our Community Water Supply has developed a service line material inventory.

To obtain a copy of the system's service line inventory: Contact Fort Massac Water District at 618-543-7475

FT MASSAC PWD IL 1275050 2024 Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1.4	1.3 – 1.4	MRDLG = 4	MRDL = 4 ppm		N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	26	13.83 – 26.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	85	35.7 – 95.1	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Violation Table			
Arsenic			
Some people who drink water containing arsenic in excess of time MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MCL, AVERAGE	01/01/2023	12/31/2025	Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL.) for the period.

Haloacetic Acids (HAAS)			
Some people who drink water containing haloacetic acids in excess of the MCL, over many years may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE (DBP), MAJOR	10/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure we cannot be sure of the quality of our drinking water during this period.

Special Notice for Availability of Unregulated Contaminant Monitoring Data

IMPORANTANT INFORMATION ABOUT YOUR DRINKING WATER

Availability of Monitoring Data for Unregulated Contaminants for:

FORT MASSAC WATER DISTRICT IL-1275050

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have the right to know that these data are available. If you are interested in examining the results, please contact David Travis at 618-543-7475 or Fort Massac Water District, P.O. Box 491, Metropolis, Illinois 62960.

Arsenic MCL Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Fort Massac Water District Has Levels of Arsenic Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received on Monday, October 7th, 2024 show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 0.010 milligrams per liter (mg/L). The average level of arsenic over the last year was 0.011 (mg/L).

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

This is a notification of your health risk due to exposure to elevated levels of arsenic.

Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What happened? What is being done?

Millstone Water District is working with its operator, engineering firm, and the Illinois EPA to make the necessary changes to our water treatment process to ensure we are doing all we can at this time to mitigate the arsenic issue. We are confident that we have taken the necessary steps for future compliance. We anticipate resolving the issue by January 1st, 2025.

For more information, please contact Ryan Travis at 618-543-7475 or PO Box 491 Metropolis, IL, 62960.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Water System ID# IL1275050 Date distributed 11/15/2024
FMWD

Monitoring Violations Annual Notice Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Fort Massac Water District

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 4th quarter of 2024 we did not complete our Haloacetic Acids monitoring before the deadline and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for this contaminant, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Haloacetic Acids	Quarterly	4	October 8 th , 2024	October 22 nd , 2024

What happened? What is being done?

We received the wrong sample bottles from the lab for the 10/8/24 monitoring schedule. We had to wait for a new set of bottles from the lab. The samples were collected as soon as the bottles arrived. The results were satisfactory. For more information, please contact David Travis at 618-543-7475 or PO Box 491, Metropolis, IL

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Fort Massac Water District.

Water System ID#

IL127-5050

Date distributed

5/14/25

MILLSTONE PWD IL1515050 2024 Regulated Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic – While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.	07/19/2021	5.98	5.98 – 5.98	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2024	0.0239	0.0239 – 0.0239	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2024	0.46	0.46 – 0.46	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium	2024	27700	27700 - 27700			ppm	N	Erosion from naturally occurring deposits; Used in water softener regeneration.

SOUTHWATER INC IL0030020 2024 Regulated Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Fluoride	07/07/2023	0.5	0.5 – 0.5	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium	05/07/2023	20200	20200 - 20200			ppm	N	Erosion from naturally occurring deposits; Used in water softener regeneration.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	09/25/2019	1.07	1.07 – 1.07	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	09/25/2019	2	2 – 2	0	15	pCi/L	N	Erosion of natural deposits.